



EFFECTIS ERA AVRASYA TEST ve BELGELENDİRME AŞ
Dilovası OSB Mahallesi Fırat Caddesi No: 18
Dilovası, Kocaeli / TÜRKİYE
www.efectis.com

DECLARATION OF TEST RESULTS

No: EEA – 1800 – 0045 – Rev1

The fire resistance test was carried out for the product as described below at Efectis Era Avrasya Test Laboratory on 08.05.2018 in accordance with the test standard:

DIN 4102-12:1998

Cable Supporting System – Power and signal cables fixed on cable trays, cable ladders and wire mesh cable tray

FIRE RESISTANCE RESULT	
Cable Tray – APK 140 15 HDG	E 30
Cable Tray – APK 530 20 PG	E 90
Cable Ladder – CKM 140 15 HDG	E 30
Cable Ladder – SKM 530 15 HDG	Non-classified
Wire Mesh Cable Tray – TOK 620 40 EG	E 90
Cable Tray – APK 530 15 HDG	E 30

Placed on the market by: METAKSAN ELEKTRİK VE İNŞAAT MALZEMELERİ SAN. VE TİC. LTD.ŞTİ.
Ortaköy Org. San. İlter Blv. 160 Ada 24 Parsel No:16 Selimpaşa-Silivri, İstanbul / TÜRKİYE

Manufacturer: METAKSAN ELEKTRİK VE İNŞAAT MALZEMELERİ SAN. VE TİC. LTD.ŞTİ.
Ortaköy Org. San. İlter Blv. 160 Ada 24 Parsel No:16 Selimpaşa-Silivri, İstanbul / TÜRKİYE

e-signed
Onur DAĞ
Chief Technical Officer
16.11.2022

This document is a declaration of test results and does not represent any type of approval or certification of the product. All details related to product specifications and field of applications are described in the report No: RFTR18064

